



TYPE TEST REPORT OF

LOW-VOLTAGE-ENCLOSED SWITCHGEAR

Report number : SG20100007

Issued date : Dec.19, 2012

Laboratory : High-Power Laboratory

Address: No. 84, Ta-An. Rd., Shulin District, New Taipei City
238, TAIWAN, R.O.C.

大電力



財團法人台灣大電力研究試驗中心
Taiwan Electric Research & Testing Center

Address : NO.6-6, Ronggong S. Rd., Caota Village,
Guanyin Township, Taoyuan County 328, Taiwan, R.O.C
TEL : (03) 483-9090
FAX : (03) 483-8119
E-Mail : customer_service@ms.tertec.org.tw
URL : www.tertec.org.tw

- ◆ The testing result is only responsible to the tested sample.
- ◆ The report can be fully duplicated only. To excerpt any part of this report is invalid unless permitted by TERTEC.
- ◆ The contents on the report can not be used for advertisement, publication and merchandised activities.
- ◆ The report is invalid if without the seal on each page.
- ◆ Inquiry telephone: +886-2-2683-9474, +886-2-2681-7233



TYPE TEST OF LOW-VOLTAGE-ENCLOSED SWITCHGEAR

Client	LONG-LITE IND.ENG. CO.,LTD.
Address	3F-3, No.31-1,Ln 169, Kangning St., Xizhi Dist., New Taipei City 221, Taiwan (R.O.C.)
Manufacturer	LONG-LITE IND.ENG. CO.,LTD.
Address	3F-3, No.31-1,Ln 169, Kangning St., Xizhi Dist., New Taipei City 221, Taiwan (R.O.C.)
Apparatus	Low-voltage metal-enclosed switchgear
Type	E-440-6300-85
Type Classification	E-type
Designation	3 ϕ 60Hz、440V、6300A、85kA(sym)x3sec、IP4X、indoor type
Serial No.	29TPCNS-02
Quantity of specimen	1 set
Applied standard	CNS 13542 C4470 & CNS 13543 C3210 (Jun.26, 1995)
Test items	Type test
Date of application	Nov.06, 2012
Date of accept	Nov.09, 2012
Date of receive	Nov.08, 2012
Date of tests	Nov.08, 2012 to Nov.16, 2012
Sample way	Voluntarily takes a sample by the Client, and carry to the laboratory
Test place	TERTEC - High Power Laboratory
Test engineer	1. TERTEC - Chih-te Hsu , Shi-Lin Lin, Yu-Ren Lin, Kun-Mou Chou, Pei-Chun Hung, Shu-Fang Chung Chi-Te Chang, Ching-hua Lin, 2. LONG-LITE IND.ENG. CO.,LTD.- Guliu Hu
Results	The client items of type test , in compliance with the standard CNS 13542 C4470 & CNS 13543 C3210 requirements.
※ Note	This report consists of 40 pages

General Manager :